



H.O.T.T.O.G.O!

HPWHs in foodservice + real-world performance

Presented at the 2026 Utility Energy Forum

Current State of the Market

Many food-service applications, from quick-service to sit-down to grocery stores

Often served by **inefficient** electric resistance or gas-fired units

Significant **savings** available!



The (Forgotten) Middle-Child of HPWHs

Most HPWHs fall into two categories:

- Small Unitary Systems (50-80 gallons)
- Large Central Systems (Often 500+ gallons)

Intermediate solutions exist:

- Small Commercial HPWHs (~120 gallons or equivalent)



Field Study Goal

Validate the performance of Small Commercial HPWH technologies:

- Unitary 120-gallon tank system
- Split system heat pump + storage tank

Recruit and monitor 26+ sites and install M&V equipment on each

This is the first-ever large-scale demonstration study of these technologies

Performance Elements


Assess the following:



System COP



Hot Water Flow



Performance Drivers





M&V Data

Site Breakdown

California (4)


Grocery Store x 2 (Vista and Encinitas, CA)

Sit-Down Diner (Sacramento, CA)

Quick-Service Restaurant (Bellflower, CA)

Texas (2)

Quick-Service Restaurant x 2 (San Antonio and Brookshire, TX)



Grocery Store #1 (Vista, CA)

Site Conditions: Indoors on a mechanical mezzanine; plentiful outside air exchange and waste heat from cooler/freezer rack compressors

Ambient Temperature: 65F to 82F

COP: 2.0 to 2.1

ER Use: <2%

Average Daily Draw: 309 gallons.

Daily Draw Range: 26-711 gal




Grocery Store #1 (Vista, CA)

Daily Hot Water Usage



Average Daily Power

09/08/25 - 01/28/26



Grocery Store #2 (Encinitas, CA)

Site Conditions: Indoors on a mechanical mezzanine; plentiful outside air exchange and waste heat from cooler/freezer rack compressors

Ambient Temperature: 61F to 78F

COP: 1.7 to 1.9

ER Use: <1%

Average Draw: 481 gallons

Draw Range: 271-811 gal



Grocery Store #2 (Encinitas, CA)



Diner (Sacramento, CA)

Site Conditions: Two 80-gal tanks located inside; four rooftop compressors

Ambient Temperature: 43F to 77F

COP: 3.5 to 4.1

ER Use: NA

Average Draw: 347 gal

Draw Range: 161-641 gal



Diner (Sacramento, CA)



Quick-Service Restaurant (Bellflower, CA)

Site Conditions: Back-of-house location; plenty of air volume; continuous recirc

Ambient Temperature: 68F to 77F

COP: 1.3 to 1.5 (due to uncontrolled recirc)

ER Use: 31%

Average Draw: 255 gal

Draw Range: 156-516 gal




Quick-Service Restaurant (Bellflower, CA)

Average Daily Power

02/07/25 - 09/21/25



Daily Hot Water Usage



Quick-Service Restaurant (San Antonio, TX)

Site Conditions: Back-of-house location;
plenty of air volume; Aquastat recirc

Ambient Temperature: 68F to 77F


COP: 2.0 to 2.3

ER Use: 49%

Average Draw: 523 gal

Draw Range: 173-971 gal

Quick-Service Restaurant (San Antonio, TX)



Quick-Service Restaurant (Brookshire, TX)

Site Conditions: Back-of-house location; plenty of air volume;
AquaStat recirc

Ambient Temperature: 66F to 71F

COP: 1.8 to 2.5

ER Use (% of total energy): 60%

Quick-Service Restaurant (Brookshire, TX)

Energy and COP








Cross-Site Analysis

Hot Water Draw Distributions


Daily Hot Water Draw by Site



Hot Water Draw Impact on COP



Ambient Temperature Impact on COP



Big Picture Takeaways



Continuous **recirculation** (uncontrolled) greatly reduces COP



Integrated units in restaurants may be **undersized** (for efficiency)



Payback period vs electric resistance only 1-2 years



Higher draw correlated with higher COP



Less clear ambient **temperature** effect